

접수번호 : 10-1920-3005
(Receipt No.)



전기용품안전인증서

Electrical Appliances Safety Certificate

안전인증번호 : SU05001-10001
(Certificate No.)

제조업자명 : Suzhou Littelfuse OVS.LTD.
(Factory)

대표자명 : Colin Mcgeary
(President)

제조공장의소재지 : 6 Xinghai street china singapore suzhou Industrial park suzhou
(Factory Address) city 215021 Jiangsu P.R.China

제품명 : 퓨즈(Fuse)
(Product)

기본모델명 : 215 250V 3.15A
(Basic Model)

정격 : T3.15AH 250V
(Rating)

파생모델명 : See the attachment 2
(Series Model)

적용기준 : K60127-1, K60127-2
(Standard)

「전기용품안전 관리법 시행규칙」 제6조제2항에 따라 위의 전기용품에 대하여 안전인증서를 발급합니다.

We issue Electrical Appliances Safety Certification as above product by Article 6 Section 2 of the Electrical Appliances Safety Control Law Enforcement Regulation.

2010년 06월 09일
year month day



한국산업기술시험원장
KOREA TESTING LABORATORY



※ 이 인증서는 「전기용품안전 관리법」에 따른 전기용품 안전성 확인에 한정된 것이며, 그 밖의 다른 법률이 적용되는 제품의 경우에는 해당 법률에 따라 추가로 인증·허가 등을 받아야 합니다.

- 첨부 : 1. 안전관리부품 및 재질목록 (List of Critical Components)
(Annex) 2. 기본모델·파생모델의 내용 (General Descriptions of Certified Products)
3. 전기용품안전인증의 변경 현황 (Status of Certificate Revisions)

□ 첨부 2 : 기본모델 · 파생모델의 내용
General description of Certified Products

| 파생모델명 Derivative model | 기본모델과의 차이점 Differences between the basic and derivative model(s) |
|---------------------------|---|
| 215 250V 4A | Rated current is changed. (T4AH 250V) |
| 215 250V 5A | Rated current is changed. (T5AH 250V) |
| 215 250V 6.3A | Rated current is changed. (T6.3AH 250V) |
| 215XE 250V 3.15A | Rated current is changed. (T3.15AH 250V) Lead wire type |
| 215XE 250V 4A | Rated current is changed. (T4AH 250V) Lead wire type |
| 215XE 250V 5A | Rated current is changed. (T5AH 250V) Lead wire type |
| 215XE 250V 6.3A | Rated current is changed. (T6.3AH 250V) Lead wire type |
| 215SP 250V 3.15A | Rated current is changed. (T3.15AH 250V) Lead wire type |
| 215SP 250V 4A | Rated current is changed. (T4AH 250V) Lead wire type |
| 215SP 250V 5A | Rated current is changed. (T5AH 250V) Lead wire type |
| 215SP 250V 6.3A | Rated current is changed. (T6.3AH 250V) Lead wire type |

제품특기사항 및 시험조건
Remarks & Test conditions

1. Test Report No. : 10-1920-3005 (2010.06.08.)

2. Product Description

- 퓨즈
- T3.15AH 250V
- Breaking capacity : 1500A
- Time-lag type
- Standard sheet 5
- High-breaking capacity

□ 본 제품의 시험내용에 관하여 문의하실 사항이 있으시면 아래 연락처로 문의하시기 바랍니다.
시험담당자 : 디지털산업본부 전기전자평가센터 조인철 / (02)860-1425

□ If you have any question on product testing, please contact the person below :
Job holder : Digital Industry Division Electric & Electronics Testing Center, INCHUL CHO/+82 2 8601-425

FP511-09-00

첨부 3 : 전기용품안전인증의 변경 현황
Status of Certificate Revisions

| 변경발급 내용 Contents of Certificate Revisions |
|--|
| Not applicable |

FP511-11-00