

Intertek

Certificate




for European Product Safety

Reference No. 1010253

Sub-miniature fuse-link

Type designation	372
Certificate holder	Littelfuse Wickmann 800 E. Northwest Highway. Des Plaines, IL 60016 UNITED STATES
The product complies with the standard(s)	EN 60127-3:1996 and A2
Date of expiry	31 December 2014
EU Directive information	The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.

Additional information in Appendix.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
Signed	 Pär Iggström	Date	22 February 2010 Page 1 of 2


This certificate is issued in accordance with the terms and conditions set out in the Appendix.

BSB

**Intertek**
Appendix

Reference No. 1010253

Technical data


Type designation	372
Rated voltage (V)	AC 250 V
Rated current (A)	50 mA; 63 mA; 80 mA; 100 mA; 125 mA; 160 mA; 200 mA; 250 mA; 315 mA; 400 mA; 500 mA; 630 mA; 800 mA; 1 A; 1.25 A; 1.6 A; 2 A; 2.5 A; 3.15 A; 4 A; 5 A; 6.3 A
Standard sheet	4
Brand name	
Product information	Time-lag, low-breaking capacity. Fuses using lead-free solder.

Manufacturing site(s) LITTELFUSE PHILIPPINES INC
Lima Technologi Center
Special Economic Zone
Lipa City-Malvar, Batangas
PHILIPPINES

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 2006/95/EC.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed


Pär Iggström

Date 22 February 2010

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.