



LITTELFUSE INC  
MR. WILLIAM TRAVIS  
800 E NORTHWEST HWY  
DES PLAINES IL 60016

**RE: Project Number(s) - 08NK23015**

Your most recent Certification is shown below. Please review the text and contact the Customer Service Professional who assisted with your project if revisions are required.

To view your company's current Listing Information or for ordering Listing Information in the 3 x 5-inch card format, please refer to www.ul.com.

**JFHR2**  
**Special-purpose Fuses - Component**

March 17, 2009

**LITTELFUSE INC**  
**800 E NORTHWEST HWY, DES PLAINES IL 60016**

**E71611**

**Cartridge fuses**, Cat. Nos. KLPC-200 through -600.  
Cat. Nos. L25S001 through -800.  
Cat. Nos. L50S001 through -030 .  
Cat. Nos. L50S035 through -800.  
Cat. Nos. L70S001 through -800.  
Cat. Nos. L17T70 through -800A, -1200A .  
Cat. Nos. LDC150 through -600.  
Cat. Nos. KLC-0 through -800.  
Cat. Nos. JLLS-900, -1000, -1100, -1200.  
Cat. Nos. TLS1 through -125, rated 1-125A, 170 Vdc.  
Cat. Nos. TLS-351 through -70L, TLS V1 through -70, TLS1 through 70LB, TLS1 through -100LS, rated 1-100A, 170 Vdc, TLS-1MB through -100MB, rated 1-100A, 170 Vdc.  
Cat. No. TLN1-600, rated 1-600A, 170V dc.  
Type MIDI, Part. No. 498 040 through 100, Series 498xxxMXT 040 through 100.  
Series 297 followed by 002 through 030, rated 2-30A, 32 Vdc / 125 Vac.  
Series 298 followed by 080 through 200, rated 80-200A, 32 Vdc.  
Series 299 followed by 020, 030, 040, 050, 060, 070 or 080, rated 20-80A, 32 Vdc.  
Series 446, 447 followed by 002, 003, 004, 005, 07.5 or 010, may be followed by "P", rated 2, 3, 4, 5, 7.5, 10A, 350 Vac, 446, 447 followed by 003, may be followed by "P", rated 3A, 140 Vac.  
Series 495, Jcase, followed by 020, 030, 040, 050 or 060, rated 20, 30, 40, 50, 60A, 58 Vdc.  
Cat. No. 496, followed by 100, 150 or 200 rated 100, 150 and 200A, 32V dc.  
Cat. No. 257APC rated 1-40A, 32 Vdc; Cat. No. 257003 rated 3A, 32 Vdc, 32 Vac.  
Cat. No. 257-3A, 25 Vac/32 Vdc.  
Cat. No. JLLS 0-30V, JLLS 0-30LS rated 1-30A, 600 Vac.  
Cat. No. LGD 35-60A, 600 Vac.  
Cat. Nos. LVSP-5-2, LVSP-5-R, LVSP-10-2, LVSP-10-R, LVSP-15-2, LVSP-15-R, LVSP-20-2, LVSP-20-R, LVSP-30, LVSP-30-2, LVSP-80, LVSP-80-2, LVSP-100-XL.  
Models LVSP-40, LVSP-40-2, LVSP-40-P, LVSP-60, LVSP-60-2.  
**Fuses for protection of semi-conductor devices**, Cat. No. 481 with suffixes 0.18 through 020, rated 125 V ac and 125 dc.  
**Fuses for protection of semi-conductor devices**, Cat. Nos. LA100P10004, LA100P1004, LA100P4T1, LA100P1254, LA100P1254T1, LA100P1504, LA100P1504TI, LA100P2004, LA100P2004TI, LA100P201, LA100P2254, LA100P2504, LA100P3004, LA100P3004TI, LA100P3504, LA100P3504TI, LA100P354, LA100P4004, LA100P4004TI, LA100P404, LA100P5004, LA100P5004TI, LA100P504, LA100P504TI, LA100P6004, LA100P6004TI, LA100P604, LA100P604TI, LA100P704, LA100P804, LA15QS1000128, LA15QS1000128IL, LA15QS1000128IL, LA15QS1200128, LA15QS1500128, LA15QS1500128IL, LA15QS2000128, LA15QS2000128IL, LA15QS2500128, LA15QS2500128IL, LA15QS3000128, LA15QS3000128IL, LA15QS3500128, LA15QS4000128, LA15QS4000128IL, LA15QS10004TI, LA15QS10004IL, LA15QS704, LA15QS704TI, LA15QS804, LA15QS804TI, LA15QS904, LA15QS1004, LA15QS1004TI, LA15QS1304, LA15QS1304TI, LA15QS1504, LA15QS1504IL, LA15QS1504TI, LA15QS2004, LA15QS2004IL, LA15QS2504, LA15QS2504TI, LA15QS3004, LA15QS3004IL, LA15QS3004TI, LA15QS3504, LA15QS3504TI, LA15QS4004,





For use only in equipment where the acceptability of the combination is determined by Underwriters Laboratories Inc.