

RESISTANCE @ +25°C = 10,000 Ω NOMINAL
ACCURACY (0 TO +70°C) = ± 0.20°C
RESISTANCE/TEMPERATURE CURVE = "J"
BETA "β" (0 TO +50°C) = 3,892°K NOMINAL
TEMPERATURE COEFFICIENT @ +25°C = −4.4%/°C NOMINAL
MAXIMUM TEMPERATURE RATING = +150°C

MAXIMUM TEMPERATURE FOR BEST LONG TERM STABILITY = +120°C

*** ROHS COMPLIANT ***

SEE MANUFACTURING SPECIFICATION (LAYER 1)

REV	REVISION RECORD	DATE	APP
NONE	RELEASE TO PRODUCTION	09/30/10	DD

SCALE	NONE
DRAWN BY	DAN DANKERT
DATE	09/30/10
REV.	NONE
LAYER	0 OF 2

© COPYRIGHT

U.S. SENSOR CORP.

714-639-1000 www.ussensor.com

NTC THERMISTOR PROBE

P/N USP11491