Intertek ETL SEMKO

Certificate

for European Product Safety

Reference No. 608508

Fuse-holder for miniature fuse-link

Type designation	824
Certificate holder	**Littelfuse Wickmann** **800 E. Northwest Highway.** **Des Plaines, IL 60016** **USA**
The product complies with the standard(s)	EN 60127-6:1994 and A1+A2
Date of expiry	31 December 2009
EU Directive information	*The product satisfies the provisions for CE marking according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.*

Terms in Intertek Semko's Agreement on certification. Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification *Place* Kista - Stockholm

Signed Alve Nilsson *Date* 31 August 2006

LCIE

Intertek ETL SEMKO

Appendix

Reference No. 608508

Technical data

Type designation	824
Rated voltage (V)	250
Rated current (A)	6,3
Rated power (W)	4
Protection against electric shock referring to fuse-holder	Category PC2
Overvoltage category	III
Pollution degree	3
Brand name:	
Product information	With fuse-carrier type 835 for fuse-links 5 x 20 mm. For panel mounting by moulding.

Manufacturing site(s)

Schurter AG
Werkhofstrasse 8-12
CH-6002 Luzern
SWITZERLAND

Schurter SSRO (GmbH)
Malá Skalá 190
CZ-468 22 Zelezny Brod
CZECH REPUBLIC

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.

Certification Body Intertek Semko AB, Product Certification *Place* Kista - Stockholm

Signed Alve Nilsson *Date* 31 August 2006

CBF