



JFGA.E339112 Fuses for Photovoltaic Systems

[Page Bottom](#)

Fuses for Photovoltaic Systems

[See General Information for Fuses for Photovoltaic Systems](#)

LITTELFUSE INC
SUITE 500
8755 W HIGGINS RD
CHICAGO, IL 60631 USA

E339112

Cat. No.	Interrupting Capacity			Rating		
	Volts		Amps	Volts		Amps
	DC	AC		DC	AC	
SPFx, where x is replaced with 001-030 (ampere rating), may be followed by -R	1000	—	20,000	1000	—	1-30
SPFJ 70 - 200	1000	—	20,000	1000	—	70-200
SPFJ 250-400	1000	—	10,000	1000	—	250-400
SPFJ 450	1000	—	20,000	1000	—	450
SPFJxxxL where XXX is replaced with 125-200	1000	—	20,000	1000	—	125-200
KLK Dx, where x is replaced with 0.1-30 (ampere rating), may be followed by -R	600	—	10,000	600	—	0.1-30
SPXVxxx, where XXX is replaced with 006-012 (ampere rating)	1500	—	15,000	1500	—	6-12
SPXVxxx, where XXX is replaced with 015-020 (ampere rating)	1500	—	15,000	1500	—	15-20
SPXVxxx, where XXX is replaced with 025-030 (ampere rating)	1500	—	15,000	1500	—	25-30

Last Updated on 2013-09-27

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2014 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2014 UL LLC".