

Certificate



for European Product Safety

Reference No. 608494

Fuse-holder for miniature fuse-link

Type designation 601

Certificate holder **Littelfuse Wickmann**
800 E. Northwest Highway.
Des Plaines, IL 60016
USA

The product complies with the standard(s) EN 60127-6:1994 and A1+A2

Date of expiry 22 February 2010

EU Directive information *The product satisfies the provisions for CE marking according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.*

Terms in Intertek Semko's Agreement on certification. Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed


Alve Nilsson

Date 30 August 2006



Appendix

Reference No. 608494

Technical data

Type designation	601
Rated voltage (V)	250
Rated current (A)	6,3
Rated power (W)	4
Protection against electric shock referring to fuse-holder	Category PC2
Overvoltage category	III
Pollution degree	3
Brand name:	
Product information	For panel mounting. With fuse-carrier type 602 (IP40) or 602-04 (IP54) for fuse-links 5 x 20 mm.

Manufacturing site(s)	Schurter AG Werkhofstrasse 8-12 CH-6002 Luzern SWITZERLAND Schurter SSRO (GmbH) Malá Skalá 190 CZ-468 22 Zelený Brod CZECH REPUBLIC
-----------------------	--

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
Signed	 Alve Nilsson	Date	30 August 2006