

# Certificate



Group Asia

Certificate no.

T 50239752 01

**License Holder:**

Suzhou Littelfuse OVS Ltd  
6 Xinghai Street  
Suzhou Industrial Park  
Suzhou, Jiangsu 215021  
P.R. China

**Manufacturing Plant:**

Suzhou Littelfuse OVS Ltd  
6 Xinghai Street  
Suzhou Industrial Park  
Suzhou, Jiangsu 215021  
P.R. China

Test report no.: ZTW2-KSH 15056216 001

Client Reference: W.W.

Tested to: UL 248-1:2011  
UL 248-14:2010

**Certified Product:** (Catridge Fuses)

**License Fee - Units**

Type Designation : 326  
Rated Voltage : AC 250V  
Rated Frequency : 50/60Hz  
Rated Current : 12A;15A and 20A  
Rated Breaking Capacity : 400A at 125/250VAC  
Dimension : 6,35mm\*31,75mm

5

**Remark:**


More information refer to Appendix 1.

Appendix: 1



5

**Licensed Test mark:**



**TÜV Rheinland Taiwan Ltd.**

Signature

**Date of Issue**

(day/mo/yr)

16/11/2012

Dipl.-Ing. W. Feuker

# Certificate



Certificate no.

T 50239752 02

**License Holder:**

Littelfuse Inc.  
O'Hare Plaza II Ste 500  
8755 W. Higgins Rd.  
Chicago, IL 60631  
USA

**Manufacturing Plant:**

Suzhou Littelfuse OVS Ltd  
6 Xinghai Street  
Suzhou Industrial Park  
Suzhou, Jiangsu 215021  
P. R. China

Test report no.: KSH 15056216 002

Client Reference: W.W.

Tested to: UL 248-1:2011  
UL 248-14:2010

Certified Product: (Miniature fuse-link#

License Fee - Units


as page 0001

Change

Name of License Holder : See above

Address of License Holder : See above

Licensed Test mark:



TÜV Rheinland (China) Ltd.

Signature

*Zhao Xinhua*  
Zhao Xinhua



Date of Issue  
(day/mo/yr)

19/03/2018

TÜV Rheinland (China) Ltd

No. 01/03B-08, Floor 7 and No. 01/04B-08, Floor 11, AVIC Building, No.10B, Central Road, East 3rd Ring Road,  
Chaoyang District, Beijing, P.R. China