

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge Protective Device

Name and address of the applicant

DongGuan Littelfuse Electronics Co., Ltd
Nanfang East Road, Beice, Humen, 523925 Dongguan, Guangdong Province,
China

Name and address of the manufacturer

DongGuan Littelfuse Electronics Co., Ltd
Nanfang East Road, Beice, Humen, 523925 Dongguan, Guangdong Province,
China

Name and address of the factory

Note: When more than one factory, please report on page 2

☐ Additional information on page 2DongGuan Littelfuse Electronics Co., Ltd
Nanfang East Road, Beice, Humen, 523925 Dongguan, Guangdong Province,
China

Ratings and principal characteristics

Test class II / Type 2, IP66;
Uc = 320 V~, In = 5 kA, I_{max} = 10 kA, I_{scrr} = 300 A;
Up = 1300 V (L-N), Up = 1800 V (L-PE, N-PE);
Maximum overcurrent protection: 20 A gG fuse

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

LSP05G277SXXXXX

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

This certificate replaces NL-40516 dated on 2016-03-30 due to technical modification.

A sample of the product was tested and found to be in conformity with

IEC 61643-11:2011

National differences:

EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

3182815.50 and 6094457.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands