

# Certificate



for European Product Safety

Reference No. 608487

## Fuse-holder for miniature fuse-link

Type designation 852, 853

Certificate holder **Littelfuse Wickmann**  
800 E. Northwest Highway.  
Des Plaines, IL 60016  
USA

The product complies with the standard(s) EN 60127-6:1994 and A1+A2

Date of expiry 31 December 2011

EU Directive information *The product satisfies the provisions for CE marking according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.*

Terms in Intertek Semko's Agreement on certification. Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed

  
Alve Nilsson

Date 29 August 2006



## Appendix

Reference No. 608487

### Technical data

Type designation	852, 853
Rated Voltage (V)	250
Rated Current (A)	6,3
Rated Power (W)	2W (5x20 mm)
Protection against electric shock referring to fuse-holder	Category PC2
Overvoltage category	III
Pollution degree	3
Product information	For PC board mounting, vertical. With fuse-carrier type 855 or 856

Manufacturing site(s) Schurter SSRO (GmbH)  
Malá Skalá 190  
CZ-468 22 Zelezny Brod  
CZECH REPUBLIC

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed

  
\_\_\_\_\_  
Alve Nilsson

Date 29 August 2006