


Certificate



Reference No. 608488

Fuse-holder for miniature fuse-link

Type designation 656, 658

Certificate holder **Littelfuse Wickmann**
800 E. Northwest Highway.
Des Plaines, IL 60016
USA

The product complies with the standard(s) EN 60127-6:1994 and A1+A2


Date of expiry 31 December 2011

EU Directive information *The product satisfies the provisions for CE marking according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.*

Technical data

Terms in Intertek Semko's Agreement on certification. Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification *Place* Kista - Stockholm

Signed 
Alve Nilsson *Date* 29 August 2006



Appendix

Reference No. 608488

Type designation	656
Rated Voltage (V)	250
Rated Current (A)	10
Rated Power (W)	4W (5x20 mm)
Protection against electric shock referring to fuse-holder	Category PC1
Overvoltage category	III
Pollution degree	3
Product information	For PC board through hole mounting. With fuse cover type 659


Type designation	658
Rated Voltage (V)	250
Rated Current (A)	10
Rated Power (W)	4W (5x20 mm)
Protection against electric shock referring to fuse-holder	Category PC1
Overvoltage category	III
Pollution degree	3
Product information	For PC board mounting, reflow-soldering. With fuse cover type 659

Manufacturing site(s) Schurter SSRO (GmbH)
Malá Skalá 190
CZ-468 22 Zelezný Brod
CZECH REPUBLIC

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed



Alve Nilsson

Date 29 August 2006