



## JDYX2.E67006 Fuses, Supplemental - Component

[Page Bottom](#)

### Fuses, Supplemental - Component

[See General Information for Fuses, Supplemental - Component](#)

#### LITTELFUSE WICKMANN WERKE

E67006

SUITE 500  
8755 W HIGGINS RD  
CHICAGO, IL 60631 USA

#### Supplemental fuses

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
201	5.2 x 20 (0.20 x 0.79)	0.032 - 0.16	250Vac	80
		0.17 - 0.4	250Vac	80
		0.5 - 1.25	250Vac	80
354	6.3 x 32 (0.25 x 1.26)	1 - 10	440Vac	1000
356	6.3 x 32 (0.25 x 1.26)	1 - 10	440Vac	1000
462	4.4 x 10.8 (0.17 x 0.43)	0.5 - 1.6	350Vac	100
		0.5 - 1.6	350Vdc	100
		2 - 5	250Vac	150
		2 - 5	250Vdc	150
		2 - 4	350Vac	100
		2 - 4	350Vdc	100

#### Supplemental fuses: pigtail leads

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
150	-	3.0	350Vac	-

#### Supplemental fuses: filled-tube

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
358	6.3 x 32 (0.25 x 1.26)	3.15 - 10	500Vac	1500
		3.15 - 10	50Vdc	250
TE7 807	12.4 x 6.4 x 9.2 (0.49 x 0.25 x 0.36)	0.2 - 2.5	300Vac	100
		3.15 - 6.3	300Vac	100

0.2 - 2.5	300Vac	5
3.15 - 6.3	300Vac	12.6

**Supplemental micro fuses**

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
<b>369</b>	8.4 x 3.9 x 7.4 (0.33 x 0.15 x 0.29)	5.0 - 6.3	300Vac	50
		0.8	250Vac	25
		5.0 - 6.3	250Vac	10x Ampere rating
		1.0 - 2.5	250Vac	25
		1.0 - 4.0	300Vac	50
		3.15 - 4.0	250Vac	10x Ampere rating
		0.8	300Vac	50
<b>375</b>	8.5 x 8.0 (0.33 x 0.31)	5 - 6.3	250Vac	63
<b>389</b>	8.5 x 4.0 x 8.5 (0.33 x 0.16 x 0.33)	0.06	250Vac	10
<b>392</b>	8.4 x 3.9 x 7.4 (0.33 x 0.15 x 0.29)	5 - 6.3	250Vac	10x Ampere rating
		5 - 6.3	250Vac	50
		1.0 - 2.5	250Vac	25
		1.0 - 2.5	250Vac	50
		3.15 - 4.0	250Vac	10x Ampere rating
		3.15 - 4.0	250Vac	50
		0.8	250Vac	25
		0.8	250Vac	50
<b>393</b>	8.5 x 4.0 x 8.5 (0.33 x 0.16 x 0.33)	3.0	250Vac	30
<b>399</b>	8.4 x 3.9 x 8.0 (0.33 x 0.15 x 0.31)	0.125 - 4.0	65Vac	50
		0.125 - 4.0	65Vdc	50
<b>TE5 808</b>	8.9 x 4.6 x 8.9 (0.35 x 0.18 x 0.35)	1 - 5	250Vac	200
		1 - 2.5	450Vdc	10000
		3.0 - 3.15	350Vdc	10000
		4 - 5	250Vdc	10000

**Supplemental micro fuses: cartridge enclosed**

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
<b>370, 19370</b>	-	0.04 - 0.08	250Vac	50
		0.1 - 0.315	250Vac	50
		0.4 - 0.8	250Vac	50
		1 - 5	250Vac	50
		6.3	250Vac	50

<b>372, 19372</b>	-	0.04 - 0.8	250Vac	50
		1 - 6.3	250Vac	50
<b>391</b>	8.4 x 3.9 x 8.0 (0.33 x 0.15 x 0.31)	0.125 - 0.2	65Vac	50
		0.125 - 0.2	65Vdc	50
		0.25 - 4.0	65Vac	50
		0.25 - 4.0	65Vdc	50
<b>398</b>	8.4 x 3.9 x 8.0 (0.33 x 0.15 x 0.31)	0.125 - 4.0	65Vac	50
		0.125 - 4.0	65Vdc	50
<b>TIP385</b>	8.3 x 3.9 x 7.7 (0.33 x 0.15 x 0.30)	0.35 - 0.5	125Vac	50
		1.5	125Vac	50
		0.8 - 1.25	125Vac	50

**Supplemental micro fuses: filled-tube**

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
<b>400</b>	8.4 x 3.9 x 7.4 (0.33 x 0.15 x 0.29)	0.5 - 6.3	250Vac	130

**Supplemental micro fuses: filled-tube, cartridge enclosed**

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
<b>382</b>	-	10.0	320Vac	50
		10.0	250Vac	100
		1.0 - 8.0	250Vac	100
		1.0 - 8.0	320Vac	50
<b>383</b>	-	10.0	320Vac	50
		10.0	250Vac	100
		1.0 - 4.0	300Vac	100
		1.0 - 8.0	250Vac	100
		1.0 - 8.0	320Vac	50



Marking: Company name or trademark and model designation.  
 Last Updated on 2012-12-20

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2013 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the

data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2013 UL LLC".